



COMMONWEALTH of VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY
DRAFT PERMIT April 30, 2019
TO WITHDRAW GROUNDWATER IN THE
EASTERN SHORE GROUNDWATER MANAGEMENT AREA

Permit Number: GW0076000

Effective Date: XX XX, 2019

Expiration Date: XX XX, 2034

Pursuant to Section 62.1-256 of the Ground Water Management Act of 1992 (Chapter 25, Title 62.1 of the Code of Virginia) and the Groundwater Withdrawal Regulations (Regulations) (9VAC25-610-10 *et seq.*), the State Water Control Board (Board) hereby authorizes the Permittee to withdraw and use groundwater in accordance with this permit.

Permittee Danny Huynh

Facility Tai Dat, LLC.

Facility Address 28267 Turkey Run Road

Mappsville, VA 23401

The Permittee's authorized groundwater withdrawal shall not exceed:

9,400,000 gallons per year,
2,500,000 gallons per month,

The permitted withdrawal will be used to provide an agricultural water supply. Other uses are not authorized by this permit.

The Permittee shall comply with all conditions and requirements of the permit.

By direction of the State Water Control Board, this Permit is granted by:

Signed _____

Date _____

Director, Office of Water Supply

Draft April 30, 2019

This permit is based on the Permittee's application submitted on February 26, 2018, and subsequently amended to include supplemental information provided by the Permittee. The following are conditions that govern the system set-up and operation, monitoring, reporting, and recordkeeping pertinent to the Regulations.

Part I Operating Conditions

A. Authorized Withdrawal

1. The withdrawal of groundwater shall be limited to the following wells identified in the table below. Withdrawals from wells not included in Table 1 are not authorized by this permit and are therefore prohibited. 9VAC25-610-140.A

Table 1

Owner Well Name	DEQ Well #	Well Depth (ft)	Screen Intervals	Aquifer*	Latitude	Longitude	Datum
Well 1	100-001575	300	280-300	Lower Yorktown- Eastover	37° 50' 55.68"	-75° 34' 42.53"	WGS84
Well 2	100-001576	300	280-300	Lower Yorktown- Eastover	37° 50' 56.8"	-75° 34' 42.31"	WGS84
Well 3	100-001577	300	280-300	Lower Yorktown- Eastover	37° 50' 59.71"	-75° 34' 52.79"	WGS84
Well 4	100-001578	300	280-300	Lower Yorktown- Eastover	37° 50' 58.63"	-75° 34' 53.47"	WGS84
Well 5	100-001579	300	280-300	Lower Yorktown- Eastover	37° 50' 57.59"	-75° 34' 50.59"	WGS84
Well 6	100-001580	300	280-300	Lower Yorktown- Eastover	37° 50' 58.99"	-75° 34' 51.42"	WGS84
Well 7	100-001581	300	280-300	Lower Yorktown- Eastover	37° 50' 58.20"	-75° 34' 43.68"	WGS84
Well 8	100-001582	300	280-300	Lower Yorktown- Eastover	37° 50' 56.87"	-75° 34' 47.96"	WGS84

*Aquifer in use was estimated based on the USGS Eastern Shore Hydrogeologic Framework and will be updated using site-specific geophysical data collected as required by the permit.

2. Any actions that result in a change to the well operation, construction, or pump intake setting of wells included in this permit must be pre-approved by the Department of Environmental Quality (Department) in writing prior to implementing the change and a revised GW-2 Form must be submitted to the Department within 30 days after the physical construction of a well is altered or the pump intake setting has been changed. If changes are a result of an emergency, notify the Department within 5 days from the change. 9VAC25-610-140.C

B. Pump Intake Settings

1. The Permittee shall not place a pump or water intake device lower than the top of the uppermost confined aquifer that a well utilizes as a groundwater source or lower than the bottom of an unconfined aquifer that a well utilizes as a groundwater source in order to prevent dewatering of the aquifer, loss of inelastic storage, or damage to the aquifer from compaction. 9VAC25-610-140.A.6

2. Pump settings in individual wells are limited as follows. Any change in the pump setting must receive prior approval by the Department.

Owner Well Name	DEQ Well #	Max Pump Setting (feet below land surface)*
Well 1	100-001575	268
Well 2	100-001576	268
Well 3	100-001577	268
Well 4	100-001578	268
Well 5	100-001579	268
Well 6	100-001580	268
Well 7	100-001581	268
Well 8	100-001582	268

*Max pump settings were estimated based on the USGS Eastern Shore Hydrogeologic Framework. Following the collection of the geophysical log data required by this permit, updated site-specific maximum pump setting depths will be provided by the Department to replace these estimated limits.

C. Reporting

1. Water withdrawn from each well shall be recorded consistently at the end of each month and reported to the Office of Water Supply, in paper or electronic format, on a form provided by the Department by the tenth (10th) day of each January, April, July and October for the respective previous calendar quarter. Records of water use shall be maintained by the Permittee in accordance with Part III.F, 1 through 5 of this permit.9VAC25-610-140.A.9
2. The Permittee shall report any amount in excess of the permitted withdrawal limit by the fifth (5th) day of the month following the month when such a withdrawal occurred. Failure to report may result in compliance or enforcement activities. 9VAC25-610-140.C
3. The following is a summary of reporting requirements for specific facility wells:

Owner Well Name	DEQ Well #	Reporting Requirements
Well 1	100-001575	Water Use
Well 2	100-001576	Water Use
Well 3	100-001577	Water Use
Well 4	100-001578	Water Use
Well 5	100-001579	Water Use
Well 6	100-001580	Water Use
Well 7	100-001581	Water Use
Well 8	100-001582	Water Use

D. Water Conservation and Management Plan

1. The Water Conservation and Management Plan (WCMP) submitted in the application received (June 12, 2018) and subsequently amended and then approved by the Department is incorporated by reference into this permit and shall have the same effect as any condition contained in this permit and may be enforced as such.
2. By the end of the first year of the permit cycle (XX XX, 2020) the Permittee shall submit a detailed description of their leak detection and repair program activities and documentation to the

Department that these activities have been conducted. This documentation shall include frequency of the activities completed and the findings and results of the activities during the first year of the permit term. 9VAC25-610-100.B.1.b,2.b,or 3.b

3. As soon as completed but not later than the end of the second year of the permit cycle (XX XX, 2021), the Permittee shall submit to the Department results of a 12 month audit of the total amount of groundwater used in the distribution system and the separate amounts used for drinking and cooling. This audit report shall include the flock cycle start and end dates during the year, and any necessary changes to the leak detection and repair program or operations that affected water use. 9VAC25-610-100.B.1.b,2.b,or 3.b
4. A report on the plan's effectiveness in maintaining or reducing water use and a summary of proposed revisions to the WCMP to address any elements that can be improved based on operations to date shall be submitted by the end of years five (XX XX, 2024) and ten (XX XX, 2029) of the permit term. These reports shall include as appropriate: 9VAC25-610-140.C
 - a. Any new water saving equipment installed or water saving processes adopted;
 - b. A summary of the operation of the cooling system for the houses during the report period including what months the cooling system was operated;
 - c. Evaluation of the leak detection and repair program with a summary of any significant leaks found and repaired; and
 - d. A summary of the flock cycles and overall water use patterns for each year covered by the report.
5. If revisions or additions to the plan are necessary an updated WCMP shall be submitted to the Department for approval along with the report prior to implementation of the revised plan
6. Records of activities conducted pursuant to the WCMP are to be submitted to DEQ upon request.

E. Mitigation Plan

The Mitigation Plan approved on (June 22, 2018) by the Department is incorporated by reference into this permit and shall have the same effect as any condition contained in this permit and may be enforced as such. 9VAC25-610-110.D.3.g

F. Well Tags

1. Each well that is included in this permit shall have affixed to the well casing, in a prominent place, a permanent well identification plate that records, at a minimum, the DEQ well identification number, the groundwater withdrawal permit number, the total depth of the well, and the screened intervals in the well. Such well identification plates shall be in a format specified by the Board and are available from the Department. 9VAC25-610-140.A.12
2. Well tags shall be affixed to the appropriate well casing within 30 days of receiving the tags from the Department. The accompanying well tag installation certification form shall be returned to the Department within 60 days of receipt of the tags. 9VAC25-610-140.C

Part II Special Conditions

Pursuant to 9VAC25-610-140.B and C, the following Special Conditions apply to this permit in order to protect the public welfare, safety, and health or conserve, protect and help ensure the beneficial use of groundwater.

A. Geophysical Log Data Collection

By August 31, 2022, a complete suite of geophysical logs (Spontaneous Potential, Single Point Resistance, 16/64 Short and Long Normal, Natural Gamma at a scale of 20 ft per inch) shall be obtained from at least 3 boreholes at the locations and depths approved by the Department during the coordination process. Given the unknown hydrogeology at the site and the known potential for significant horizontal variability, additional geophysical logs may be required as determined by the Department during the drilling work to assess the well field area. An electronic and hard copy of the geophysical logs shall be submitted to the Department within 30 days of collection to allow determination of the top and bottom of the aquifer in use. 9VAC25-610-140.C

At least two months prior to the scheduled geophysical logging, the Permittee shall notify the Department of the drilling timetable to receive any further guidance needed on performing the geophysical logging and to allow scheduling of Department staff to make a site visit during the drilling of the borehole and/or the geophysical logging. Geophysical log data collected without the oversight of the Department will not be accepted.

B. Pump Intake Determination and Reset

Within 90 days of notification of the maximum pump setting depth as determined by Department staff based on new geophysical log data obtained by the Permittee as required by the permit, the Permittee shall submit documentation from a certified well provider, or other source as accepted by the Department, that the pump intake for each production well is set above the setting stated in the notification

C. Meter Installation Verification/Correction

If notified by DEQ through an inspection report that meters meeting the requirements set forth in Part III Condition I of this permit have not been correctly installed on each production well in such a manner as to record total withdrawals from the well including both cooling water and drinking water, the Permittee shall correct any identified meter issues within 60 days of notification.

D. Alternative Source Investigation

1. By September 30, 2023 the Permittee shall conduct an investigation of the surficial aquifer (Columbia) to evaluate the ability of the surficial aquifer to provide all or part of the water supply needs for the facility. The investigation shall include water quality and pump test data collected from a surficial aquifer test well constructed on-site with Department oversight to ensure the well is properly screened in the surficial aquifer. A geophysical log shall be obtained from the surficial aquifer test well per Part III.K of the permit unless a geophysical log collected from an existing production well is accepted by DEQ as representing the Columbia aquifer at the test well location. An existing well screened in the surficial aquifer located on or near the facility property may be used where approved by DEQ as an alternative. An existing well must have sufficient well construction information available to verify it is screened in the surficial aquifer and properly constructed in order to be considered.
2. A report on the results of the investigation shall be provided to DEQ by March 31, 2024.

Part III General Conditions

A. Duty to Comply

The Permittee shall comply with all conditions of the permit. Nothing in this permit shall be construed to relieve the permit holder of the duty to comply with all applicable federal and state statutes, regulations and prohibitions. Any permit violation is a violation of the law and is grounds for enforcement action, permit termination, revocation, modification, or denial of a permit application. 9VAC25-610-130.A

B. Duty to Cease or Confine Activity

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the activity for which a permit has been granted in order to maintain compliance with the conditions of the permit. 9VAC25-610-130.B

C. Duty to Mitigate

The Permittee shall take all reasonable steps to avoid all adverse impacts that may result from this withdrawal as defined in 9VAC25-610-10 and provide mitigation of the adverse impact when necessary as described in 9VAC25-610-110.D.3.g. 9VAC25-610-130.C

D. Inspection, Entry, and Information Requests

Upon presentation of credentials, the Permittee shall allow the Board, the Department, or any duly authorized agent of the Board, at reasonable times and under reasonable circumstances, to enter upon the Permittee's property, public or private, and have access to, inspect and copy any records that must be kept as part of the permit conditions, and to inspect any facilities, well(s), water supply system, operations, or practices (including sampling, monitoring and withdrawal) regulated or required under the permit. For the purpose of this section, the time for inspection shall be deemed reasonable during regular

business hours. Nothing contained herein shall make an inspection time unreasonable during an emergency. 9VAC25-610-130.D

E. Duty to Provide Information

The Permittee shall furnish to the Board or Department, within a reasonable time, any information that the Board may request to determine whether cause exists for modifying or revoking, reissuing, or terminating the permit, or to determine compliance with the permit. The Permittee shall also furnish to the Board or Department, upon request, copies of records required to be kept by regulation or this permit. 9VAC25-610-130.E

F. Monitoring and Records Requirements

1. The Permittee shall maintain a copy of the permit on-site and/or shall make the permit available upon request. 9VAC25-610-130.E
2. Monitoring of parameters shall be conducted according to approved analytical methods as specified in the permit. 9VAC25-610-130.F.1
3. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. 9VAC25-610-130.F.2
4. The Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart or electronic recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three years from the date of the expiration of a granted permit. This period may be extended by request of the Board at any time. 9VAC25-610-130.F.3
5. Records of monitoring information shall include as appropriate: 9VAC25-610-130.F.4
 - a. the date, exact place and time of sampling or measurements;
 - b. the name(s) of the individual(s) who performed the sampling or measurements;
 - c. the date the analyses were performed;
 - d. the name(s) of the individual(s) who performed the analyses;
 - e. the analytical techniques or methods supporting the information, such as observations,
 - f. readings, calculations and bench data used;
 - g. the results of such analyses; and
 - h. chain of custody documentation.

G. Environmental Laboratory Certification

The Permittee shall comply with the requirement for certification of laboratories conducting any tests, analyses, measurements, or monitoring required pursuant to the State Water Control Law (§ [62.1-44.2](#) et seq.), Environmental Laboratory Certification Program (§ 2.2-1105 et seq.), Certification for Noncommercial Environmental Laboratories (1VAC30-45), and/or Accreditation for Commercial Environmental Laboratories (1VAC30-46), and

- a. Ensure that all samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. Conduct monitoring according to procedures approved under 40CFR Part 136 or alternative methods approved by the U.S. Environmental Protection Agency.
- c. Periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals that will ensure accuracy of measurements. (1VAC30-45-20)

H. Future Permitting Actions

1. A permit may be modified or revoked as set forth in Part VI of the Regulations. 9VAC25-610-290 and 9VAC25-610-130.G
2. If a Permittee files a request for permit modification or revocation, or files a notification of planned changes, or anticipated noncompliance, the permit terms and conditions shall remain effective until the Board makes a final case decision. This provision shall not be used to extend the expiration date of the effective permit. 9VAC25-610-130.G
3. Permits may be modified or revoked upon the request of the Permittee, or upon Board initiative, to reflect the requirements of any changes in the statutes or regulations. 9VAC25-610-130.G
4. The Permittee shall schedule a meeting with the Department prior to submitting a new, expanded or modified permit application. 9VAC25-610-85
5. A new permit application shall be submitted 270 days prior to the expiration date of this permit, unless permission for a later date has been granted by the Board, to continue a withdrawal greater than or equal to 300,000 gallons in any month while an application for a renewal is being processed. 9VAC25-610-96
6. A new permit application shall be submitted 270 days prior to any proposed modification to this permit that will (i) result in an increase of withdrawal above permitted limits; or (ii) violate the terms and conditions of this permit. 9VAC25-610-96
7. The applicant shall provide all information described in 9VAC25-610-94 for any reapplication. 9VAC25-610-96.C
8. The Permittee must notify the Department in writing of any changes to owner and facility contact information within 30 days of the change. 9VAC25-610-140.C

I. Metering and Equipment Requirements

1. Each well and/or impoundment or impoundment system shall have an in-line totalizing flow meter to read gallons, cubic feet, or cubic meters installed prior to beginning the permitted use. Meters shall produce volume determinations within plus or minus 10% of actual flows. 9VAC25-610-140.A.7.b
 - a. A defective meter or other device must be repaired or replaced within 30 days.
 - b. A defective meter is not grounds for not reporting withdrawals. During any period when a meter is defective, generally accepted engineering methods shall be used to estimate withdrawals. The period during which the meter was defective must be clearly identified in the groundwater withdrawal report required by Part I, Subsection D of this permit. An alternative method for determining flow may be approved by the Board on a case-by-case basis.
2. Each well shall be equipped in a manner such that water levels can be measured during pumping and non-pumping periods without dismantling any equipment. Any opening for tape measurement of water levels shall have an inside diameter of at least 0.5 inches and be sealed by a removable plug or cap. The Permittee shall provide a tap for taking raw water samples from each permitted well. 9VAC25-610-140.A.7.e

J. Minor Modifications

1. A minor modification to this permit must be made to replace an existing well(s) or add an additional well(s) provided that the well(s) is screened in the same aquifer(s) as the existing well(s), and is in the near vicinity of the existing well(s), the total groundwater withdrawal does not increase, the area of impact does not increase, and the well has been approved by the Department prior to construction. 9VAC25-610-330.B.4 and 5
2. A minor modification to this permit must be made to combine withdrawals governed by multiple permits when the systems are physically connected as long as interconnection will not result in additional groundwater withdrawal and the area of impact will not increase. 9VAC25-610-330.B.6
3. Minor modifications to this permit must also be made to:
 - a. Change an interim compliance date up to 120 days from the original compliance date, as long as the change does not interfere with the final compliance date. 9VAC25-610-330.B.7
 - b. Allow for change in ownership when the Board determines no other change in the permit is necessary and the appropriate written agreements are provided in accordance with the transferability of permits and special exceptions. 9VAC25-610-320 and 9VAC25-610-330.B.8
 - c. Revise a Water Conservation and Management Plan to update conservation measures being implemented by the Permittee that increase the amount of groundwater conserved. 9VAC25-610-330.B.9

K. Well Construction

At least 30 days prior to the scheduled construction of any well(s), the Permittee shall notify the Department of the construction timetable and receive prior approval of the well(s) location(s) and acquire the DEQ Well number. All wells shall be constructed in accordance with the following requirements.

1. A well site approval letter or well construction permit must be obtained from the Virginia Department of Health prior to construction of the well. 9VAC25-610-130.A
2. A complete suite of geophysical logs (Spontaneous Potential, Single Point Resistance, 16/64 Short and Long Normal, Natural Gamma) shall be completed for the well and submitted to the Department along with the corresponding completion report. 9VAC25-610-140.C
3. The Permittee shall evaluate the geophysical log and driller's log information to estimate the top of the target aquifer and; therefore, a depth below which the pump shall not be set. The Permittee's determination of the top of the target aquifer shall be submitted to the Department for review and approval, or approved on site by the Department's Groundwater Characterization staff, prior to installation of any pump. 9VAC25-610-140.A.6
4. The Permittee shall install gravel packs and grout in a manner that prevents leakance between aquifers. Gravel pack shall be terminated close to the top of the well screen(s) and shall not extend above the top of the target aquifer. 9VAC25-610-140.C
5. A completed GW-2 Form and any additional water well construction documents shall be submitted to the Department within 30 days of the completion of any well and prior to the initiation of any withdrawal from the well. 9VAC25-610-140.C. The assigned DEQ Well number shall be included on all well documents. 9VAC25-610-140.C
6. In addition to the above requirements, construction of a Water Level Monitoring State Observation Well (SOW) requires:
 - a. The Permittee shall coordinate activities with the Department's Groundwater Characterization Program (GWCP) to determine the appropriate observation well location and construction schedule, along with the needed screen interval(s), and other completion details following review of geophysical logging. 9VAC25-610-140.C
 - b. Prior to preparation of bid documents for construction of the observation well, the Permittee shall notify the Department and shall include any GWCP requirements in the bid documents. At a minimum, the Department will require a pre-bid meeting with interested drilling contractors and a pre-construction meeting with the successful bidder. 9VAC25-610-140.C
 - c. Instrumentation to meet the requirements for real-time data transmission consistent with the State Observation Well Network shall be purchased by the Permittee. The Permittee shall submit a purchase order based on the Department's equipment specifications for review and approval prior to purchase of the equipment. The Permittee shall not be required to install the equipment. 9VAC25-610-140.C
7. In addition to the above requirements, construction of a Chloride Monitoring SOW requires:

- a. The Permittee shall coordinate activities with the Department's Groundwater Characterization Program (GWCP) to determine the appropriate observation well location and construction schedule, along with the needed screen interval(s), and other completion details following review of geophysical logging. 9VAC25-610-140.C
- b. Prior to preparation of bid documents for construction of the observation well, the Permittee shall notify the Department and shall include any GWCP requirements in the bid documents. At a minimum, the Department will require a pre-bid meeting with interested drilling contractors and a pre-construction meeting with the successful bidder. 9VAC25-610-140.C
- c. Instrumentation to meet the requirements for real-time data transmission consistent with the State Observation Well Network shall be purchased by the Permittee. The Permittee shall submit a purchase order based on the Department's equipment specifications for review and approval prior to purchase of the equipment. The Permittee shall not be required to install the equipment. 9VAC25-610-140.C
- d. Instrumentation to meet the requirements for continuous measurement of specific conductance from multiple levels within the well screen shall be purchased by the Permittee. The Permittee shall submit a purchase order based on the Department's equipment specifications for review and approval prior to purchase of the equipment. The Permittee shall not be required to install the equipment. 9VAC25-610-140.C

L. Permit Reopening

This permit may be reopened for the purpose of modifying the conditions of the permit as follows:

- a. To meet new regulatory standards duly adopted by the Board. 9VAC25-610-140.A.11
- b. When new information becomes available about the permitted withdrawal, or the impact of the withdrawal, which had not been available at permit issuance and would have justified the application of different conditions at the time of issuance. 9VAC25-610-310.B.1
- c. When the reported withdrawal is less than 60% of the permitted withdrawal amount for a five year period. 9VAC25-610-310.B.2
- d. If monitoring information indicates the potential for adverse impacts to groundwater quality or level due to this withdrawal. 9VAC25-610-140.C

COMMONWEALTH of VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY

PERMIT ISSUANCE FACT SHEET

Groundwater Withdrawal Permit Number: GW0076000

Application Date: December 13, 2017

The Department of Environmental Quality (Department or DEQ) has reviewed the application for a Groundwater Withdrawal Permit. Based on the information provided in the application and subsequent revisions, DEQ has determined that there is a reasonable assurance that the activity authorized by the permit is a beneficial use as defined by the regulations. Groundwater impacts have been minimized to the maximum extent practicable. The following details the application review process and summarizes relevant information for developing the Permit and applicable conditions.

Permittee / Legal Responsible Party

Name & Address: Danny Huynh
28261 Turkey Run Road
Bloxom, VA 23308
Phone: (281) 999-8999

Facility Name and Address

Name & Address: Tai Dat, LLC.
28267 Turkey Run Road
Mappsville, VA 23401
Phone: (281) 999-8999

Contact Information:

Name: Danny Huynh
E-mail: DH9998999@yahoo.com
Phone: (281) 999-8999

Proposed Beneficial Use:

The proposed use for this withdrawal is for agriculture. Withdrawals will supply a poultry growing operation with water for cooling of chicken houses as well as for direct consumption by poultry.

Processing Dates

Processing Action	Date Occurred/Received
Pre-Application Meeting:	November 1, 2017
Application Received:	February 26, 2018
Permit Fee Deposited by Accounting:	Not Applicable
Notice of Deficiency Sent	March 1, 2018
Response to Notice of Deficiency Received:	May 16, 2018
Local Government Ordinance Form Received:	April 24, 2018
Application Complete:	June 22, 2018
Submit Request for Technical Evaluation:	December 18, 2018
Technical Evaluation Received:	February 14, 2019
Draft Permit Package Sent:	April 30, 2019
Submit Draft Permit for Public Notice:	Mo Dy, 2019
Public Notice Published:	Mo Dy, 2019
End of 30-Day Public Comment Period:	Mo Dy, 2019
Response to Public comment:	Mo Dy, 2019
Public Meeting or Hearing:	TBD

Application

Application Information

Tai Dat, LLC. is a poultry farm owned by Danny Huynh and located in Accomack County. Tai Dat, LLC. has 10 poultry houses and 8 production wells. The houses are sized as follows: 10 houses of 66 ft. by 600 ft.. The farm produces broilers. Additional information on how water is used at the farm is discussed in the basis of need section of the fact sheet.

The property was purchased in 2016 and wells were constructed in November and December of 2017. A DEQ geologist was not on-site during the well drillings and it appears no geophysical logs were collected as wells were constructed. Originally 10 wells were planned; however, only 8 wells were drilled, and the additional 2 wells are not planned for construction during this permit term.

Location of Facility/Withdrawal:

Water Supply Planning Unit: Accomack & Northampton

County: Accomack County

GWMA/Aquifer: Eastern Shore/Lower Yorktown-Eastover

Conjunctive Use Source: This system uses no surface water and is therefore not a conjunctive use system.

Withdrawal Use, Current Need, and Projected Demand:

Basis of Need: Poultry farms use groundwater to provide drinking water to the birds as well as to supply water to either misting systems or evaporative cooling pads designed to regulate temperatures in the house and keep the birds cool. Cooling is primarily required in summer.

Water use for poultry farms varies seasonally as well as in response to the poultry life cycle. Generally during winter, fall, and spring, facility withdrawals rise and fall in a predictable pattern every 50-60 days, or the length of time it takes to raise a flock, with increased usage primarily resulting from increased water consumption as the birds gain weight. This water use pattern starts with low water consumption volumes for chick development and peaks in the last 20-30 days as growers seek to maximize adult weight gains. Typically, farms raise around five flocks per year with this cycle repeating each time. During the summer, withdrawal volumes increase due to additional water usage for flock cooling purposes.

Water volumes used for consumption are controlled by a computer system that provides water to the drinker system, which provides access to water for the birds but limits spillage or excess moisture from entering the house. Avoiding excess moisture is critical to bird health and as a result careful conservation of water is already a key tenet of management in a broiler house. The computer tracks water supplied to the drinking system and records the volume. This data was maintained by some farms but in many cases was not recorded long-term. Where available, data from the computer is discussed in the historic withdrawals section of the factsheet.

The cooling systems are operated based on temperature and humidity and while usage is typically restricted to summers, operation of the cooling systems tends to vary between farms. Historically, water supplied to the cooling systems was not metered so very limited data is available on usage.

Water Demand Projection: Water demands were based on estimated drinking and cooling water amounts needed to supply all the system houses. Proposed withdrawal limits were calculated based on the total of both consumption (drinking water) and cooling. Water use for consumption was originally calculated based upon generalized numbers provided by the primary poultry provider, Tyson, as no historical data was available; however, this data appears to have overestimated usage by using a maximum daily value instead of accounting for the cyclical and season trends associated with a poultry farm. Revised calculations were later provided based upon the "Poultry Water Use Calculation" guidance provided by DEQ and using consumption figures from nearby comparable farms as a starting point.

As no data on volumes used for cooling was available from farms operating on the shore, a procedure for estimating water use for cooling was developed for use based on discussions with industry stakeholders, individual farmers, and a review of available literature. House size and cooling fan capacity were identified as the major variables determining water use for cooling poultry houses. A formula based on 1.6 gallons per year per cubic foot per minute (cfm) of cooling fan capacity was determined to be representative for the Delmarva area poultry industry. The major variable for cooling fan capacity is the width of the house as that provides for the number and size of cooling fans that can be installed. The combined total width of the houses for the facility was used as the basis to estimate cooling water use. The water use calculations are attached to the fact sheet as Attachment 4. The permit requires metering of the wells to record total water use and actual amounts used for cooling will be collected.

A small amount of water is used for general farm operation including washing equipment and cleaning houses between flocks. An amount of 100,000 g/y was estimated for these uses.

Water demands are not expected to change as the amount requested represents the maximum capacity of the farm and no additional houses are considered in this permit. Therefore, no projections are included for this facility.

Withdrawal Volumes Requested: The applicant originally requested 28,365,000 annually and 3,720,000 monthly; however, after recalculating needs based upon the cooling calculation procedure noted above, the following withdrawal volumes were requested based upon the projected groundwater demand.

Period of Withdrawal	Actual Volume (gal.)	Volume in MGD
Maximum Monthly:	2,500,000	.081
Maximum Annual:	9,400,000	.026

DEQ Evaluation

Historic Withdrawals: No record of historic withdrawals was available for this facility as the facility was recently constructed. Refer to the DEQ Water Demand Projections section above for more information on how water use was estimated.

Analysis of Alternative Water Supplies: The Eastern Shore of Virginia is an area primarily served by groundwater with the majority of withdrawals coming from the three confined Yorktown-Eastover (Upper/Middle/Lower) aquifers. There is limited surface water availability with the majority of streams being too small to supply sufficient water for most purposes, larger water bodies are typically tidally influenced, and water quality concerns have limited the development of these sources. Withdrawals from the surficial aquifer, or water table, are one viable alternative to withdrawals from the confined system. While withdrawals from the surficial aquifer can present additional water quality challenges in the form of iron forming bacteria and increased vulnerability to surface contaminants, it may be viable in some locations where capacity and quality are sufficient. In general, drinking water for poultry must be of higher quality than the cooling water. In most cases, site-specific data will be necessary to determine the viability of the surficial aquifer and to determine what portions of the use it can supply.

Public Water Supply: The proposed withdrawal does not contain a public water supply component.

Water Supply Plan Review: A Water Supply Planner coordination request was sent on September 10, 2018 and a response was received on January 9, 2019. The response noted several key items.

The Accomack County Regional Water Supply Plan (Plan) includes irrigating agricultural facilities using both groundwater and surface water, with current permitted amounts sufficient to meet demands into 2040. The plan, however, does not include existing poultry farms in their assessments. While the seafood industry could also show future growth in the region, Section 4.0 of the ANPDC Groundwater Management Plan details industrial water for seafood and poultry processing, noting over 90% of industrial groundwater usage is related to poultry processing. WSP Staff note existing water quality concerns for surface waters and no significant water

surpluses or sources in Accomack County to serve as alternative sources. Additionally, WSP staff reviewed the current alternatives under consideration, such as water table wells, and noted that the ability of the National Resources Conservation Service's (NRCS) Environmental Quality Incentives Program (EQIP) program to fund such efforts is currently unknown. The current lack of inclusion of poultry in the region's plan, existing water quality and alternative source concerns, and the unknown status of funding for alternative development underlines potential regional resource concerns to be addressed in future planning efforts.

DEQ Recommended Withdrawal Limits: The recommended withdrawal limits are based on the total of both consumption (drinking water) and cooling. Water use for consumption was evaluated based on data from a comparable farm. The consumption data from a comparable farm was provided and DEQ staff reviewed the data and determined it provided a reasonable basis for estimating monthly and annual consumption for the facility.

DEQ staff evaluated the volumes requested for cooling and determined they were accurately calculated using the procedure discussed in more detail above. Given the lack of data available for evaluating poultry water use, DEQ believes the methods employed are conservative enough to provide sufficient water for the farm to continue operation while still providing a reasonable limit for the permits. It is expected that as more metered data becomes available, withdrawal limits may be reduced in cases where actual water use is significantly lower than the permit limits.

Withdrawal limits were rounded to nearest hundred thousand in accordance with DEQ's April 6, 2015 "Rounding Memo". DEQ recommends the following withdrawal volumes based upon evaluation of the groundwater withdrawal permit application.

Period of Withdrawal	Actual Volume (gal.)	Volume in MGD
Maximum Monthly:	2,500,000	.081
Maximum Annual:	9,400,000	.026

Technical Evaluation: Aquaveo, LLC performed a technical evaluation of the application for the Department based on the VAHydroGW-ES model. As an aquifer pump test was not performed, the properties from the VAHydroGW-ES model were used to simulate the potential drawdown resulting from the proposed withdrawal. The model uses a base simulation which includes all existing permits (except the applicant wells) operating at their 2017 maximum annual withdrawal limit allowed under the terms of their permit for all Ground Water Management Area (GWMA) permit holders. This base simulation is then executed for 50 years. A second 50-year simulation was then conducted using the VAHydroGW-ES model with the applicant's proposed withdrawals added to the base simulation to simulate drawdown resulting from the applicant's wells using the proposed withdrawal volumes. The objectives of this evaluation were to determine the areas of any aquifers that will experience at least one foot of water level decline due to the proposed withdrawal (the Area of Impact or AOI), to determine the potential for the proposed withdrawal to cause salt-water intrusion, and to determine if the proposed withdrawal meets the 80% drawdown criteria. A summary of the results of the evaluation are provided below and the full technical evaluation is attached to this fact sheet as Attachment 1.

Aquaveo, LLC reviewed and compared simulated 2017 water levels from the reported use to USGS measured water levels in observation wells closest to the applicant's withdrawal for the same year for the Upper, Middle, and Lower Yorktown-Eastover aquifers. Comparing the

VAHydroGW-ES 2017 Historic Use Water Level with the USGS Network Well 2017 Water Level provides a method for judging the accuracy of the VAHydroGW-ES model. Aquaveo noted that the water levels obtained from the regional observation networks are a few feet higher for the Upper Yorktown-Eastover aquifer and 0.5 to 14 feet higher for the Middle and Lower Yorktown-Eastover aquifers. Aquaveo also noted that the observed water levels in all three aquifers exhibit yearly fluctuations in water levels of approximately 2 to 5 feet (Upper) or 2 to 10 feet (Middle and Lower). Water levels simulated by the VAHydroGW-ES do not fluctuate in the same manner because the pumping and recharge simulated in the model for any given year are averaged over the year and entered in the model as the average value for the year. Aquaveo concluded that while there are some variations between the observed and simulated water levels, the fluctuations and general patterns observed in the USGS wells are simulated by the VAHydroGW-ES model and the water levels from the two sources are in general agreement. Differences between observed and simulated water levels will be noted and addressed during the next calibration of the VAHydroGW-ES model.

The potential for adverse changes to water quality due to increases salinity resulting from the proposed withdrawal was evaluated using transient, density-dependent, SEAWAT simulations using the VAHydroGW-ES. The results indicated that no model cells simulate an increase in chloride concentration greater than 55 mg/L due to the proposed withdrawal. Therefore, the VAHydroGW-ES model results do not indicate the potential for reduced water quality.

The results of the VAHydroGW-ES simulations predict areas of impact due to the proposed withdrawal in the Lower Yorktown-Eastover aquifer. The Area of Impact (AOI), or the area in which the withdrawal is expected to result in a drawdown of at least 1 foot, extend a maximum distance of approximately 0.7 miles from the production center in the Lower Yorktown-Eastover aquifer. As the AOI extends beyond the property line, a mitigation plan is required and will be incorporated into the permit. The modeled area of impact determines the area in which the facility must evaluate any impacts according to the process laid out in the mitigation plan.

With the inclusion of the proposed withdrawal, the model simulated water levels at 9.2, 7.3, and -5.8 ft. msl for the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. The 80% drawdown criterion allows the potentiometric water level (based on the critical surface elevation calculated from the VAHydroGW-ES data) to be reduced to -70.5, -114.7, and -176.6 ft. msl for the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. Therefore, the water levels in the VAHydroGW-ES cell containing the applicant wells for each confined aquifer are not simulated to fall below the critical surface. Additionally, no new VAHydroGW-ES cells are simulated to have water levels below the critical surface. Therefore, this withdrawal is within the limits set by the 80% drawdown criterion.

Aquaveo, LLC concluded that the proposed withdrawals meet technical criteria for permit issuance. The map of the AOI is included in the attached Mitigation Plan.

Part I
Operating Conditions

Authorized Withdrawals:

Owner Well Name	DEQ Well #	Aquifer*	Type	Max Pump Setting (ft. bls)*
Well 1	100-001575	Lower Yorktown-Eastover	Production	268
Well 2	100-001576	Lower Yorktown-Eastover	Production	268
Well 3	100-001577	Lower Yorktown-Eastover	Production	268
Well 4	100-001578	Lower Yorktown-Eastover	Production	268
Well 5	100-001579	Lower Yorktown-Eastover	Production	268
Well 6	100-001580	Lower Yorktown-Eastover	Production	268
Well 7	100-001581	Lower Yorktown-Eastover	Production	268
Well 8	100-001582	Lower Yorktown-Eastover	Production	268

*Max pump settings were estimated based on the USGS Eastern Shore Hydrogeologic Framework and will be updated using site-specific geophysical data collected as required by the permit.

Apportionment:

Apportionment of withdrawals is expected to be fairly equally spread across all facility wells and the permit does not include apportionment limits.

Additional Wells:

There are no additional observation, abandoned, or out of service wells associated with this facility.

Pump Intake Settings:

All eight pumps are documented on the GW-2 forms to be set at 160 ft. bls. No geophysical log data was available for this site and therefore aquifer elevation for the top of the aquifer in use was estimated using the USGS Eastern Shore Hydrogeologic Framework. Once geophysical log data is obtained in compliance with the permit, DEQ geologists will determine the top of the aquifer in use, which will be the pump intake limit above which the pumps must be set. The permittee will have 90 days to ensure all pumps meet the intake limits once notified of the limits by DEQ.

Withdrawal Reporting:

Groundwater withdrawals are to be recorded monthly and reported quarterly.

Water Conservation and Management Plan:

A Water Conservation and Management Plan (WCMP) meeting the requirements of 9VAC25-610-100.B was submitted and reviewed as part of the application process. The accepted Plan is to be followed by the permittee as an operational Plan for the facility/water system.

- A detailed description of the leak detection and repair program activities and documentation to the Department that these activities have been conducted is due by the end of the first year of the

permit term.

- A result of a 12 month audit of the total amount of groundwater used in the distribution system and the amounts for drinking and cooling water, documentation of the flock cycle start and end dates, and any necessary changes to the operation affecting water use is due by the end of the second year of the permit term.
- A report on the plan's effectiveness in maintaining or reducing water use amounts needed, including revisions to those elements of the WCMP that can be improved and addition of other elements found to be effective based on operations to date shall be submitted by the end of years five (Mo Dy, 2024) and ten (Mo Dy, 2029) of the permit term.

Mitigation Plan:

The predicted AOI resulting from the Technical Evaluation extends beyond the property boundaries in the Lower Yorktown-Eastover aquifer. Given this prediction, a Mitigation Plan to address potential claims from existing well owners within the predicted area of impact is included in the permit by reference.

Well Tags:

Well tags will be transmitted with the final permit.

Part II Special Conditions

Geophysical Log Data Collection:

Geophysical log information is needed to evaluate the top of the aquifer in use and the regulatory permitted pump intake limit, and to determine whether the current pump settings meet regulatory limitations. The Department requires collection of a geophysical log for each new well to be included in a Groundwater Withdrawal Permit. Given the large number of wells associated with poultry facilities, the Department agreed to work with applicants that had constructed wells prior to application to allow for a reduced number of geophysical logs required to represent the wells keeping in mind the need to evaluate lateral variation in the hydrogeology. The Permittee must contact DEQ at least two months prior to scheduling the geophysical logs to allow for Department scheduling.

The collection of geophysical log data requires a borehole to be drilled at least to the depth of the deepest facility well, or an alternative depth at the discretion of the Department, and the logging equipment run down the full depth of the hole. Geophysical logging is to include 16"/64" Normal, Single Point, Self-Potential, and Natural Gamma at a scale of 20 feet per inch. Collection of a full suite of geophysical logs and a drillers log is required by August 31, 2022 at three locations with the locations and depths approved by DEQ. Additional geophysical log locations may be required by Department staff as warranted depending on site hydrogeology to evaluate lateral variation in the aquifer top elevations. These logs will be used to represent the remaining facility wells. Department staff must be present for the geophysical logging to evaluate the log and well cuttings.

Pump Intake Determination and Reset:

Within 90 days of notification of pump intake limits by the Department based on the geophysical data, the permittee shall ensure all pump intakes are set above the identified limits. The Permittee is to notify the Department of the work schedule and to submit written documentation of the pump setting within 30 days of the work.

Meter Installation/Verification:

In cases where meters are found to be incorrectly installed or otherwise failing to capture the total water use of each well, DEQ will notify the permittee of such via an inspection report and the permittee shall correct any meter issues within 60 days.

Alternative Source Investigation:

The facility is supplied by wells screened in the confined Lower Yorktown-Eastover aquifer. The confined aquifer system on the Eastern Shore is considered to be of higher quality than the surficial (water table) aquifer and is the potable water supply for the majority of the Eastern Shore. The regulation requires the lowest quality water available be applied to the permitted use. While the application states generally that the surficial aquifer would not be viable, site specific investigation is necessary to evaluate the surficial aquifer quality and availability. By September 30, 2023 an alternative source investigation must be completed and the results submitted to DEQ by March 31, 2024 for review and acceptance. The investigation shall provide pump test and water quality data from a test or production well screened in the surficial aquifer on the facility site as well as conclusions on the capability of the surficial aquifer to supply all or part of the water needs for the facility.

Part III General Conditions

General Conditions are applied to all Groundwater Withdrawal Permits, as stated in the Groundwater Withdrawal Regulations, 9VAC25-610-10 *et seq.*

Public Comment

The following sections will be completed after close of the public comment period.

Relevant Regulatory Agency Comments:

Summary of VDH Comments and Actions: This facility is not a public water supply so soliciting comments from VDH was not required.

Public Involvement during Application Process:

Local and Area wide Planning Requirements: The Accomack County Administrator indicated on April 24, 2018 that the facility's operations are consistent with all ordinances.

Public Comment/Meetings: The public notice was published in the Eastern Shore Post Mo Dy, 2019. The public comment period ran from Mo Dy, 2019 to Mo Dy, 2019.

Changes in Permit Part II Due to Public Comments

Changes in Permit Part III Due to Public Comments

Staff Findings and Recommendations

Based on review of the permit application, staff provides the following findings.

- The proposed activity is consistent with the provisions of the Ground Water Management Act of 1992, and will protect other beneficial uses.
- The proposed permit addresses minimization of the amount of groundwater needed to provide the intended beneficial use.
- The effect of the impact will not cause or contribute to significant impairment of state waters.
- This permit includes a plan to mitigate adverse impacts on existing groundwater users.

Staff recommends Groundwater Withdrawal Permit Number GW0076000 be issued as proposed.

Attachments

- 1. Technical Evaluation**
- 2. Water Conservation Plan**
- 3. Mitigation Plan**
- 4. Water Use Calculation Worksheet**
- 5. Public Comment Sheet**

Approved: _____

Director, Office of Water Supply

Date: _____

**COMMONWEALTH of VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY**

TECHNICAL EVALUATION FOR PROPOSED GROUNDWATER WITHDRAWAL

Date: December 14, 2018

Application /Permit Number: GW0076000

Owner / Applicant Name: Danny Huynh

Facility / System Name: Tai Dat LLC

Facility Type: Agriculture – Poultry Farm

Facility / System Location: Accomack County

The Commonwealth of Virginia’s Groundwater Withdrawal Regulations (9VAC25-610-110(D) state that, for a permit to be issued for a new withdrawal, to expand an existing withdrawal, or reapply for a current withdrawal, a technical evaluation shall be conducted. This report documents the results of the technical evaluation conducted to meet the requirements for the issuance of a permit to withdrawal groundwater within a Groundwater Management Area as defined in (9VAC25-600-10 et seq.).

This evaluation determines the:

- (1) The Area of Impact (AOI): The AOI for an aquifer is the areal extent of each aquifer where one foot or more of drawdown is predicted to occur as a result of the proposed withdrawal.
- (2) Water Quality: The potential for the proposed withdrawal to cause salt water intrusion into any portions of any aquifers or the movement of waters of lower quality to areas where such movement would result in adverse impacts on existing groundwater users or the groundwater resource as per (9VAC25-610-110(D)(2), and
- (3) The Eighty Percent Drawdown (80% Drawdown): The proposed withdrawal in combination with all existing lawful withdrawals will not lower water levels, in any confined aquifer that the withdrawal impacts, below a point that represents 80% of the distance between the land surface and the top of the aquifer at the points where the one-foot drawdown contour is predicted for the proposed withdrawal as per 9VAC25-610-110(D)(3)(h).

Summary of Requested Withdrawal:

General:

In response to the Department of Environmental Quality’s (DEQ) Compliance Assistance Framework initiative, a cohort of poultry farms in Accomack County were identified as potentially requiring a groundwater withdrawal permit (GWWP). The farms primarily grow broilers which are processed by several poultry integrators located in the area. These farms use groundwater to provide drinking water to the birds as well as to supply water to either misting systems or evaporative cooling pads which cool the birds. Cooling is primarily required in summer. Most wells associated with poultry farms in Accomack County are screened in either the upper, middle, or lower Yorktown-Eastover aquifers. The use of the Columbia (water-table) aquifer is being investigated by the industry and this aquifer may be used in the future to augment withdrawals from confined aquifers where possible.

Water use for poultry farms varies seasonally as well as in response to the poultry life cycle. Generally during winter, fall, and spring, facility withdrawals rise and fall in a fairly predictable pattern every 50-60 days, with usage primarily resulting from water consumption. This pattern starts with low water

consumption volumes for chick development and maxes out in the last 20-30 days as breeders seek to maximize adult weight gains. Typically, farms raise around five flocks per year with this cycle repeating each time. During the summer, withdrawal volumes increase due to additional water usage for flock cooling purposes. A few farms have additional sanitary and other agricultural uses (crops/other livestock).

Facility Specific:

Tai Dat LLC has 10 poultry houses and 8 production wells. (Two additional wells were originally planned but were not drilled.) The 10 houses are all 66 feet by 600 feet. Proposed withdrawal limits were calculated based on the total of both consumption (drinking water) and cooling. Water use for consumption was calculated based on consultant and DEQ calculation formats. Water use for cooling was calculated based on estimates established on house size and cooling fan capacity.

Volumes include additional usage for onsite residential sanitary usage.

The proposed withdrawal limits and well construction details are as follows:

Proposed Withdrawal Limits:

Proposed Withdrawal Limits	
Annual Value	9,400,000 gallons (25,753 average gpd)
Monthly Value	2,500,000 gallons (80,645 average gpd)

Proposed Apportionment of Withdrawal:

Due to the well and plumbing configuration, the withdrawal will be apportioned fairly equally between the system wells.

Production Well(s):

Identification	Location	Construction	Pump Intake	Source Aquifer
Owner Well Name: Well #1 DEQ Well Number: 100-01575 MPID: 375056075344301	Lat: 37° 50' 55.68" Lon: -75° 34' 42.53" Datum: WGS84 Elevation: 44	Completion Date: 11/8/2017 Screens (ft-bls): 280-300 Total Depth (ft-bls): 300	160	Lower Yorktown-Eastover
Owner Well Name: Well #2 DEQ Well Number: 100-01576 MPID: 375057075344202	Lat: 37° 50' 56.8" Lon: -75° 34' 42.31" Datum: WGS84 Elevation: 44	Completion Date: 11/10/2017 Screens (ft-bls): 280-300 Total Depth (ft-bls): 300	160	Lower Yorktown-Eastover

Owner Well Name: Well #3 DEQ Well Number: 100-01577 MPID: 375060075345303	Lat: 37° 50' 59.71" Lon: -75° 34' 52.79" Datum: WGS84 Elevation: 44	Completion Date: 11/15/2017 Screens (ft-bls): 280-300 Total Depth (ft- bls): 300	160	Lower Yorktown- Eastover
Owner Well Name: Well #4 DEQ Well Number: 100-01578 MPID: 375059075345304	Lat: 37° 50' 58.63" Lon: -75° 34' 53.47" Datum: WGS84 Elevation: 44	Completion Date: 11/18/2017 Screens (ft-bls): 280-300 Total Depth (ft- bls): 300	160	Lower Yorktown- Eastover
Owner Well Name: Well #5 DEQ Well Number: 100-01579 MPID: 375058075345105	Lat: 37° 50' 57.59" Lon: -75° 34' 50.59" Datum: WGS84 Elevation: 46	Completion Date: 11/22/2017 Screens (ft-bls): 280-300 Total Depth (ft- bls): 300	160	Lower Yorktown- Eastover
Owner Well Name: Well #6 DEQ Well Number: 100-01580 MPID: 375059075345106	Lat: 37° 50' 58.99" Lon: -75° 34' 51.42" Datum: WGS84 Elevation: 44	Completion Date: 11/30/2017 Screens (ft-bls): 280-300 Total Depth (ft- bls): 300	160	Lower Yorktown- Eastover
Owner Well Name: Well #7 DEQ Well Number: 100-01581 MPID: 375058075344407	Lat: 37° 50' 58.20" Lon: -75° 34' 43.68" Datum: WGS84 Elevation: 44	Completion Date: 12/2/2017 Screens (ft-bls): 280-300 Total Depth (ft- bls): 300	160	Lower Yorktown- Eastover

Owner Well Name: Well #8	Lat: 37° 50' 56.87" Lon: -75° 34' 47.96"	Completion Date: 12/5/2017	160	Lower Yorktown- Eastover
DEQ Well Number: 100-01582	Datum: WGS84 Elevation: 46	Screens (ft-bls): 280-300		
MPID: 375057075344808		Total Depth (ft-bls): 300		

Geologic Setting:

The Tai Dat LLC wells (applicant wells) are located in northern Accomack County. The production wells are screened in the Lower Yorktown-Eastover aquifer. The upper portion of the Yorktown-Eastover aquifer (described in the 2006 Virginia Coastal Plain Hydrologic Framework¹ (VCPHF) as a combination of the Upper, Middle, and Lower Yorktown-Eastover aquifers) is composed primarily of estuarine to marine quartz sands of the Yorktown Formation of Pliocene age. The nearest USGS geologic cross section found in USGS Professional Paper 1731 is cross-section GS-GS' (see attached figure at the end of the report).

Virginia Eastern Shore Model data:

The following table lists the location of the applicant production wells within the Virginia Eastern Shore Model² (VAHydroGW-ES).

VAHydroGW-ES Model Grid				
Well	Well Number	MPID	Row	Column
Well #1	100-01575	375056075344301	76	54
Well #2	100-01576	375057075344202	76	54
Well #3	100-01577	375060075345303	76	53
Well #4	100-01578	375059075345304	76	53
Well #5	100-01579	375058075345105	76	54
Well #6	100-01580	375059075345106	76	53
Well #7	100-01581	375058075344407	76	54
Well #8	100-01582	375057075344808	76	54

Hydrologic Framework:

Data from the VCPHF is reported in this technical report to illustrate the hydrogeologic characteristics of the aquifers in the Virginia Eastern Shore near the applicant wells and identify major discrepancies between regional hydrogeology and site logs interpreted by the DEQ staff geologist.

The following average aquifer elevations were estimated from the VAHydroGW-ES at the model cell(s) containing the applicant production wells.

¹ McFarland, E.R., and Bruce, T.S., 2006, The Virginia Coastal Plain Hydrogeologic Framework: U.S. Geological Survey Professional Paper 1731, 118 p., 25 pls.

² Sanford, W.E., Pope, J.P., and Nelms, D.L., 2009, Simulation of groundwater-level and salinity changes in the Eastern Shore, Virginia: U.S. Geological Survey Scientific Investigations Report 2009-5066, 125 p.

VAHydroGW-ES Average Hydrologic Unit Information		
Aquifer	Elevation (feet msl)	Depth (feet bls)
Surface	44	0
Columbia aquifer (bottom)	-36	80
Upper Yorktown-Eastover aquifer (top)	-93	137
Upper Yorktown-Eastover aquifer (bottom)	-121	165
Middle Yorktown-Eastover aquifer (top)	-148	192
Middle Yorktown-Eastover aquifer (bottom)	-205	249
Lower Yorktown-Eastover aquifer (top)	-224	268
Lower Yorktown-Eastover aquifer (bottom)	-330	374

Eastern Shore Hydrogeologic Framework Based Recommendations:

Due to a lack of geophysical borehole data, DEQ staff has reviewed available information and made the following preliminary determinations regarding the location of the aquifer tops for the following wells based upon a review of the GW-2 forms available and The Virginia Coastal Plain Hydrogeologic Framework (USGS Professional Paper 1731). Further evaluation of aquifer tops will be conducted during the upcoming permit term and as additional geophysical information becomes available.

Unit	Well #1-8 (ft-bls)
Top of the Upper Yorktown-Eastover	137
Top of the Middle Yorktown-Eastover	192
Top of the Lower Yorktown-Eastover	269

Water Level Comparison:

Below water levels retrieved from the USGS regional observation network wells are compared to the simulated water levels reported in the *Virginia Eastern Shore 2017-2018 Annual Simulation of Potentiometric Groundwater Surface Elevations of Reported and Total Permitted Use* report (the 2017-2018 report) and simulation files.³ This comparison is made in order to evaluate the performance of the regional model in the vicinity of the applicant wells and assess historical groundwater trends.

The 2017-2018 report provides two sets of simulated potentiometric water surface elevations. The VAHydroGW-ES model is divided into three parts. The first portion of the model simulates water levels within the Eastern Shore aquifers from 1900 through 2017 based upon historically reported pumping amounts (the “*Historic Use Simulation*”). This portion of the model has been calibrated to match water levels observed in USGS regional observation network wells situated throughout the peninsula. The water levels reported in the 2017-2018 report are based upon two separate simulations, each simulation running from 2018 through 2067. The simulated pumping amount in these two simulations are based upon, 1) the average 2013-2017 reported withdrawal amount of wells in the VAHydroGW-ES model (the “*Reported Use Simulation*”) and, 2) the current (2018) maximum withdrawal amount allowed under their current permit for wells in the VAHydroGW-ES model (the “*Total Permitted Simulation*”). Both these simulations are an extension of the *Historic Use Simulation* and the water levels reported in the 2017-2018 report are the final water levels simulated at the end of the simulations (2067).

³ See *Virginia Eastern Shore 2017-2018 Annual Simulation of Potentiometric Groundwater Surface Elevations of Reported and Total Permitted Use* report and simulation files on file with the VA DEQ.

The “VAHydroGW-ES 2067 Reported Use Water Level,” reported in the tables below, is the simulated water level – 50 years from present – if all permitted pumping continued at the average 2013-2017 reported withdrawal amount for the next 50 years. And the “VAHydroGW-ES 2067 Total Permitted Water Level,” reported in the tables below, is the simulated water level – 50 years from present – if all Eastern Shore permitted wells were to pump at the maximum permitted amount allowed under their current permit for the next 50 years. Finally, the “VAHydroGW-ES 2017 Historic Use Water Level,” reported in the tables below, is the water level simulated for the year 2017 in the *Historic Use Simulation*.

The nearest USGS regional observation network wells to the applicant wells, completed in the Upper, Middle, or Lower Yorktown-Eastover aquifers, are listed in the following tables and shown in Figure 1. For the USGS regional observation network wells, average 2017 reported water levels are shown in the following tables. Simulated water levels for the Upper, Middle, and Lower Yorktown-Eastover aquifers, for the VAHydroGW-ES cells containing the USGS regional observation network wells are also shown in the following tables.




Figure 1. Nearest USGS regional observation network wells.

Comparing the VAHydroGW-ES 2017 Historic Use Water Level with the USGS Network Well 2017 Water Level provides a method for judging the accuracy of the VAHydroGW-ES. Figures 2 through 9 show graphs of the recorded water levels from the USGS observation wells listed in the following tables. These figures also show the simulated VAHydroGW-ES *Historic Use Simulation* water levels for the model cell containing each USGS well. Observing the simulated and observed water elevations together provide a second method for assessing the accuracy of the VAHydroGW-ES in the vicinity of the applicant wells.

The Upper Yorktown-Eastover VAHydroGW-ES 2017 Reported Use Water Level is the same value as the USGS Network Well 2017 Water Level observed in Well 66L 2 SOW 107A; while the 2017 VAHydroGW-ES water level is a few feet higher than the level observed in Well 65K 27 SOW 114A. The water levels observed over the past approximately 40 years in both Upper Yorktown-Eastover USGS wells are shown in Figures 2 and 3. Both wells exhibit yearly fluctuations in water levels of approximately 2 to 5 feet. Water levels simulated by the VAHydroGW-ES do not fluctuate in the same manner because the pumping and recharge simulated in the model for any given year are averaged over the year and entered in the model as the average value for the year. Water levels for Well 66L 2 SOW 107A are in general agreement with the water level simulated by the VAHydroGW-ES. Water levels for Well 65K 27 SOW 114A are approximately 5 feet lower for the past decade than those simulated by the VAHydroGW-ES.

The Middle Yorktown-Eastover VAHydroGW-ES 2017 Reported Use Water Levels are one-half to 14 feet lower than the USGS Network Well 2017 Water Levels observed in Well 66L 3 SOW 107B, Well 65K 28 SOW 114B, and Well 66M 26 SOW 181D. The water levels observed over the past 30 to 40 years in the Middle Yorktown-Eastover USGS wells are shown in Figures 4 through 6. Each well exhibits yearly fluctuations in water levels of approximately 2 to 10 feet. Water levels for the USGS Middle Yorktown-Eastover wells are in general agreement with the water level simulated by the VAHydroGW-ES – especially for Well 66L 3 SOW 107B. While still reasonably accurate, water levels for 66M 26 SOW 181D are lower than and have diverged slightly from those simulated by the VAHydroGW-ES over the past 15 years. The fluctuations and general patterns observed in Well 65K 28 SOW 114B are generally simulated by the VAHydroGW-ES. The large spike in the simulated water level at the end of 2012 is due to a significant reduction in reported pumping for the year 2012 by a large, nearby withdrawal. The absence of a corresponding jump in water levels in Well 65K 28 SOW 114B indicates that the reported pumping amounts for the year 2012 may not have matched the actual pumping in the vicinity of the well.

The Lower Yorktown-Eastover VAHydroGW-ES 2017 Reported Use Water Levels are one to 14 feet lower than the USGS Network Well 2017 Water Levels observed in Well 66L 1 SOW 107C, Well 65K 29 SOW 114C, and Well 66M 25 SOW 181C. The water levels observed over the past 30 to 40 years in the Lower Yorktown-Eastover USGS wells are shown in Figures 7 through 9. Each well exhibits yearly fluctuations in water levels of approximately 2 to 10 feet. Water levels for the USGS Lower Yorktown-Eastover wells are in general agreement with the water level simulated by the VAHydroGW-ES – with the same general discrepancies noted in the Middle Yorktown-Eastover observations.

Differences between observed and simulated water levels will be noted and addressed during the next calibration of the VAHydroGW-ES.

Upper Yorktown-Eastover Measurements	66L 2 SOW 107A	65K 27 SOW 114A
Distance from applicant wells (miles)	2.8	8.9
VAHydroGW-ES Row	63	123
VAHydroGW-ES Column	61	49
VAHydroGW-ES Land Surface Elevation (ft-msl)	27	45
USGS Well Land Surface Elevation (ft-msl)	10	45
USGS Network Well 2017 Water Level (ft-msl)	0.9	-0.3
VAHydroGW-ES 2017 Reported Use Water Level (ft-msl)	0.9	2.7
VAHydroGW-ES 2067 Reported Use Water Level (ft-msl)	0.2	2.5
VAHydroGW-ES 2067 Total Permitted Water Level (ft-msl)	-0.9	-1.4

Middle Yorktown-Eastover Measurements	66L 3 SOW 107B	65K 28 SOW 114B	66M 26 SOW 181D
Distance from applicant wells (miles)	2.8	8.9	6.1
VAHydroGW-ES Row	63	123	51
VAHydroGW-ES Column	61	49	33
VAHydroGW-ES Land Surface Elevation (ft-msl)	27	45	6
Land Surface Elevation (ft-msl)	10	45	6
USGS Network Well 2017 Water Level (ft-msl)	0.5	-29	5.0
VAHydroGW-ES 2017 Reported Use Water Level (ft-msl)	0.0	-43.6	-1.1
VAHydroGW-ES 2067 Reported Use Water Level (ft-msl)	-0.7	-41.8	-1.7
VAHydroGW-ES 2067 Total Permitted Water Level (ft-msl)	-31.4	-49.4	-2.1

Lower Yorktown-Eastover Measurements	66L 1 SOW 107C	65K 29 SOW 114C	66M 25 SOW 181C
Distance from applicant wells (miles)	2.8	8.9	6.1
VAHydroGW-ES Row	63	123	51
VAHydroGW-ES Column	61	49	33
VAHydroGW-ES Land Surface Elevation (ft-msl)	27	45	6
Land Surface Elevation (ft-msl)	10	45	6
USGS Network Well 2017 Water Level (ft-msl)	-0.9	-49.2	2.1
VAHydroGW-ES 2017 Reported Use Water Level (ft-msl)	0.0	-63.6	-1.1
VAHydroGW-ES 2067 Reported Use Water Level (ft-msl)	-0.8	-61.5	-1.7
VAHydroGW-ES 2067 Total Permitted Water Level (ft-msl)	-1.9	-62.8	-2.2




Figure 2. USGS Regional Observation Well 66L 2 SOW 107A, Upper Yorktown-Eastover aquifer water levels recorded from 1977 to present (well depth 140 ft bls, land surface 10 ft msl).




Figure 3. USGS Regional Observation Well 65K 27 SOW 114A, Upper Yorktown-Eastover aquifer water levels recorded from 1980 to present (well depth 160 ft bls, land surface 45 ft msl).




Figure 4. USGS Regional Observation Well 66L 3 SOW 107B, Middle Yorktown-Eastover aquifer water levels recorded from 1977 to present (well depth 206 ft bls, land surface 10 ft msl).




Figure 5. USGS Regional Observation Well 65K 28 SOW 114B, Middle Yorktown-Eastover aquifer water levels recorded from 1980 to present (well depth 230 ft bls, land surface 45 ft msl).




Figure 6. USGS Regional Observation Well 66M 26 SOW 181D, Middle Yorktown-Eastover aquifer water levels recorded from 1987 to present (well depth 230 ft bls, land surface 6 ft msl).




Figure 7. USGS Regional Observation Well 66L 1 SOW 107C, Lower Yorktown-Eastover aquifer water levels recorded from 1977 to present (well depth 305 ft bls, land surface 10 ft msl).




Figure 8. USGS Regional Observation Well 65K 29 SOW 114C, Lower Yorktown-Eastover aquifer water levels recorded from 1980 to present (well depth 315 ft bls, land surface 45 ft msl).




Figure 9. USGS Regional Observation Well 66M 25 SOW 181C, Lower Yorktown-Eastover aquifer water levels recorded from 1987 to present (well depth 340 ft bls, land surface 6 ft msl).

Aquifer Test(s):

An aquifer test has not been conducted for this system and the VAHydroGW-ES model was used to evaluate the application. The following table provides the average hydrogeologic properties assigned to the VAHydroGW-ES cell(s) containing the applicant wells.

Virginia Eastern Shore Model Hydrogeologic Properties: Row 76/Column 53 & 54							
Aquifer	Top Elevation (feet msl)	Top Elevation (feet bls)	Aquifer Thickness (feet)	Horizontal Conductivity (feet/day)	Vertical Conductivity (feet/day)	Specific Storage (1/feet)	Specific Yield
Columbia	44	0	80	72	0.5	0.00001	0.15
Upper Yorktown-Eastover	-93	137	28	9	4.8	0.000004	N/A
Middle Yorktown-Eastover	-148	192	58	13	21.0	0.000004	N/A
Lower Yorktown-Eastover	-224	268	105	6	4.0	0.000004	N/A

Model Results

Evaluation of Withdrawal Impacts:

The VAHydroGW-ES model was used to simulate the effects resulting from the proposed withdrawal due to the multi-aquifer impacts. The stabilized effects resulting from the proposed withdrawal were simulated at the annual permitted withdrawal rate of 9,400,000 gallons per year (25,753 average gpd). The stabilized effects were simulated by replacing the reported use amounts in the 2017 VAHydroGW-ES Reported Use Simulation with the current maximum annual withdrawal limit allowed under the terms of their permit for all Ground Water Management Area (GWMA) permit holders. That same simulation

was executed twice, once with the proposed withdrawal removed (the *baseline simulation*), and once with the proposed withdrawal added (the *proposed withdrawal simulation*). The stabilized effects of the proposed withdrawal were considered by simulating both simulations for 50 years and observing the difference in water potentiometric levels at the end of the simulations.

Area of Impact:

The area of impact (AOI) for an aquifer is the area where the additional drawdown due to the proposed withdrawal exceeds one foot. The results of the VAHydroGW-ES simulations, outlined in the preceding section, predict an area of impact in the Lower Yorktown-Eastover aquifer. The AOI area extends a maximum distance of approximately 0.7 miles from the production center for the Lower Yorktown-Eastover aquifer. AOI maps for all affected aquifers are attached to this report.

80 % Drawdown:

The 80% drawdown criterion was evaluated for all impacted, confined aquifers in the Virginia Eastern Shore using the VAHydroGW-ES *proposed withdrawal simulation*. The elevations of the top of the Upper, Middle, and Lower Yorktown-Eastover aquifers at the VAHydroGW-ES cell (row 76, column 54) simulating the greatest drawdown are -93, -148, and -224 feet msl, respectively. Based on the results of the *proposed withdrawal simulation* the predicted potentiometric water levels at the same VAHydroGW-ES cell are 9.2, 7.3, and -5.8 feet msl for the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. The 80% drawdown criterion allows the potentiometric water level (based on the critical surface elevation calculated from the VAHydroGW-ES data) to be reduced to -70.5, -114.7, and -176.6 feet msl in the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. Therefore, the water levels in the VAHydroGW-ES cell containing the applicant wells for each confined aquifer are not simulated to fall below the critical surface. Additionally, no new VAHydroGW-ES cells are simulated to have water levels fall below the critical surface. Therefore, this withdrawal is within the limits set by the 80% drawdown criterion.

The requested withdrawal is allocated 100% to the Lower Yorktown-Eastover aquifer. The technical evaluation analysis indicated that the apportionment of the requested withdrawal amount among the applicant production wells had no significant effect on the outcome of the technical evaluation.

Water Quality:

The EPA has established the National Secondary Drinking Water Regulations (NSDWRs) which are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic (such as taste, odor, or color) effects in drinking water. The EPA recommends the secondary standards to water systems – states may choose to adopt them as enforceable standards. The EPA NSDWRs specify the limit on chloride as 250 mg/L.

The VAHydroGW-ES was created "to help the Commonwealth and local water managers better plan water use and estimate future changes in water and salinity levels in response to changes in water use."⁴ Use of the model to predict future chloride concentrations results in a "general useful understanding of system behavior, but water-resource managers must be careful in trusting the accuracy of predictions at individual wells from a regional model."⁵ Further, chloride concentrations at individual wells, predicted using the regional model, should not be relied upon to predict actual concentrations at those locations.

The potential for adverse changes to water quality due to the requested withdrawal was evaluated using transient, density-dependent, SEAWAT simulations using the VAHydroGW-ES. Two simulations were

⁴ Sanford, W.E., Pope, J.P., and Nelms, D.L., 2009, Simulation of groundwater-level and salinity changes in the Eastern Shore, Virginia: U.S. Geological Survey Scientific Investigations Report 2009–5066, 125 p.

⁵ Sanford, W.E. and Pope, J.P., 2009, Current challenges using models to forecast seawater intrusion: lessons from the Eastern Shore of Virginia, USA. Hydrogeology Journal (2009), Volume: 18, Issue: 1, p: 73-93

executed – one simulation without the proposed withdrawal included and a second with the proposed withdrawal included. Both simulations were executed for 50 years. And both used the 2017 total permitted stresses, concentrations, and heads as starting conditions. In an effort to simulate the long-term effects on water quality due to the proposed withdrawal, the amount of 9,400,000 gallons per year (25,753 average gpd) was used for the duration of the second simulation. The two simulations were compared to evaluate the potential for adverse changes to water quality. The results indicated that no model cells simulate an increase in chloride concentration greater than 55 mg/L due to the proposed withdrawal. Therefore, the VAHydroGW-ES model results do not indicate the potential for reduced water quality as a result of the proposed withdrawal.

Conclusion:


The withdrawal requested by Danny Huynh for the Tai Dat LLC withdrawal satisfies the technical evaluation criteria for permit issuance. The AOI for the Lower Yorktown-Eastover aquifer is shown in the following map. The existing permitted wells located within the applicant's AOI are listed in the following table.

Lower Yorktown-Eastover Aquifer – Existing Permittees within the Tai Dat LLC AOI

Permittee	Permit	Well	Latitude	Longitude
Levi Farms LLC	GW0074300	100-01614	37.858434	-75.57561
	GW0074300	100-01615	37.857961	-75.576117
	GW0074300	100-01616	37.85749	-75.576613
	GW0074300	100-01617	37.857129	-75.577449
	GW0074300	100-01619	37.856407	-75.57809
	GW0077900	100-01476	37.848768	-75.576612
Turkey Run Farm	GW0077900	100-01477	37.848448	-75.576779
	GW0077900	100-01478	37.848607	-75.575826
	GW0077900	100-01479	37.848186	-75.576055
	GW0077900	100-01480	37.84757	-75.575447
	GW0077900	100-01481	37.847012	-75.573601
	GW0074300	100-01614	37.858434	-75.57561

Tai Dat LLC

Area of Impact - Lower Yorktown-Eastover Aquifer



● Tai Dat LLC Wells



○ Lower Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Lower Yorktown-Eastover aquifer resulting from a 9,400,000 gallons per year (25,753 average gpd), 50 year, Lower Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.

Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.7 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018





Coastal Plain (2006) Cross-Sections GS-GS' from USGS Professional Paper 1731.

TAI DAT FARM – TAI DAT LLC WCM PLAN

Introduction

Tai Dat Farm is a contract broiler farm that produces chicken for meat production. The facility consists of 10 chicken houses in the town of Mappsville in Accomack County, Virginia. The Farm fully understands the need to be a good steward of the region's limited groundwater resources. As a result, key operational and design considerations were made to minimize the use and loss of water in Tai Dat Farm Water Supply System.

This Water Conservation and Management Plan is designed to optimize the Farm groundwater supply and consists of the following elements:

- Practicable Water Saving Equipment and Processes
- Water Loss Reduction Program
- Water Use Education Program
- Evaluation of Practicable Water Reuse Options
- Mandatory Water Use Reductions during Shortages.

Practicable Water Saving Equipment and Processes

The Farm requirements for water saving equipment and processes are implemented primarily through upgrading of equipment and maintenance of the most water efficient poultry houses. Drinker systems for all facilities are designed to provide clean, cool water with adequate flow rate fundamental to food poultry production. The use of closed nipple drinker systems ensures minimal waste of water and precludes the requirement for daily cleaning, which also conserves overall water usage. Flow rates are regularly checked and water consumption is monitored daily with any substantial change in water usage investigated. Evaporative Cooling Pads are utilized only at temperatures above 82° F and recirculate water until evaporated in order to conserve water while still meeting their designed purpose of providing temperature relief in hot conditions for efficient poultry production. The troughs are constructed of corrosion proof, ultraviolet stabilized PVC components to eliminate bacteria and algae growth. Management techniques that do not involve water consumption are also utilized in hot conditions such as walking the birds and feed removal.

The Farm management diligently seeks to save water. The saving of water reduces the electrical cost for running the well pumps, storage tanks, float switch and booster pumps. Management at the Farm will regularly review water consumption electronically and by I-Phone apps which alerts the farmer or staff of any below average or abnormal variations in the system. These variations that are monitored are air, moisture, temperature, and electric power. If the power goes down, there are stand-by diesel- driven generators to be used to provide electric to the houses and wells. Underground water leakage detection can only be determined by spikes in the water meter rates. Once a rate increase is noted or an alert goes out over the cell app, the owner and staff search to discover the location of the leak(s) and repairs begin within the hour after it has been discovered.

TAI DAT FARM – TAI DAT LLC WCM PLAN, PAGE 2

Water Loss Reduction Program

Water Loss Audit

If granted a permit Tai Dat Farm will implement a water audit program within the first 24 months of the permit term. The audit and monthly inspections should eliminate leakage problems by early detection and will be conducted prior to and continue after the audit has been implemented. Annually a water loss audit will be conducted to determine the volume and nature of lost and unaccounted-for water within the water supply system. The purpose of the audit is

to identify sources of demand that would normally escape detection by the metering system. This type of demand includes:

1. Main Flushing. All main flushing performed by the PWS will require the submittal of a water consumption estimate.
2. Tank Drainage. All draining of storage tanks in the main distribution system to detect leaks.
3. Main Breaks. All main breaks will require the reporting by PWS personnel of the estimated volume of water lost.

Leak Detection and Repair from Distribution System

This farm is monitored on a 24 hours basis by the owner/facility's manager and one or two onsite workers. The houses' cooling and watering systems are inspected and repaired after each flock reaches maturity. All repairs are completed before the next flock comes in. Underground water leakage detection can only be determined by spikes in the water meter rates. Once a rate increase is noted or an alert goes out over the cell app, the owner and staff immediately search to discover the location of the leak(s) and repairs begin within the hour after it has been discovered.

Leak Detection and Repair for Individual Chicken Houses

The Farm staff and management team will pay close attention to abnormal water consumption and if the house controller indicates a higher than normal water requirement, staff and management will come together to find and repair the leaks within the hour after it has been discovered.

Water Use Education Program

Employee Training

All employees on the Tai Dat Farm are encouraged to conserve water and identify potential leaks when hired, during training, and the use of regular conversational reminders and may be required to attend any DPI classes offered.

TAI DAT FARM- TAI DAT LLC WCM PLAN, PAGE 3

Specifically, employees will be instructed in the ways in which they could use less water (or no water) for a given task.

Evaluation of Practicable Water Reuse Options

This is an existing Farm and therefore have limited opportunities to explore water reuse projects for Poultry Farm. The likelihood of a reuse project occurring is remote at this time, given the current water-saving equipment in place and inability to practicably treat collected storm water to standards or quality that can be utilized for flock consumption. The use of nearby surface water would not be sufficient for consumption purposes due to the Water Quality and the possibility of disease found in the local wildlife and waterfowl. The most notable being Bird flu, or Avian Influenza, which can be spread by waterfowl to flocks. These flocks are constantly and carefully immunized to prevent the spread of diseases and to promote healthy birds, and water quality plays a major role in flock health. Should a water use arise that could utilize non-potable water, then a Water Re-use Evaluation will be conducted at that time.

Mandatory Water Use Reductions during Shortages

The facility will comply with all applicable sections of the Accomack County Drought Response and Contingency Plan as identified in the Accomack County Water Supply Plan. This includes voluntary water use restrictions in drought watch and mandatory water use restrictions in a drought emergency. Personnel will be instructed to conserve water and advised of any water use restrictions that may be in place and that the waste of water generally will not be permitted for the duration of a water shortage emergency. Under mandatory water reductions during shortages, it is not feasible to reduce the amount of water which is needed to be provided in order to produce healthy birds.

The only waste water produced by these facilities is the water used to wash off the cooling coils and cooling fans. During emergency water shortages, air may be used to dislodge dust particles from this equipment.

MITIGATION PLAN

DEQ GROUNDWATER WITHDRAWAL PERMIT NO. GW00760000

OWNER NAME: Danny P. Huynh

FACILITY NAME: Tai Dat LLC

LOCATION: 28267 Turkey Run Road Mappsville, Virginia 23407

INTRODUCTION

On March 26, 2018, Danny P. Huynh submitted a Groundwater Withdrawal Permit Application to the Virginia Department of Environmental Quality (DEQ) to withdraw groundwater. Groundwater withdrawals associated with this permit will be utilized to supply a poultry operation.

The purpose of this Mitigation Plan is to provide existing groundwater users a method to resolve claims that may arise due to the impact of the withdrawal from Tai Dat Farm well field. Predicted drawdown of water levels due to the withdrawal(s) from the Yorktown Eastover-aquifers in use by the facility wells aquifer(s) are shown in the attached maps(s).

Modeled impacts, as shown on the attached maps, extend beyond the boundary of the Tai Dat Farm facility. Due to these findings, Danny P. Huynh recognizes that there will be a rebuttable presumption that water level declines that cause adverse impacts to existing groundwater users within the area of impact are due to this withdrawal. Claims may be made by groundwater users outside this area; however, there is a rebuttable presumption that Danny P. Huynh / Tai Dat Farm has not caused the adverse impact. Danny P. Huynh proposes this plan to mitigate impacts to existing users and excludes impacts to wells constructed after the effective date of this permit.

CLAIMANT REQUIREMENTS

To initiate a claim, the claimant must provide written notification of the claim to the following address:

Contact Name	<u>Danny P. Huynh</u>
Title	<u>Owner</u>
Permittee Name	<u>Tai Dat LLC</u>
Address	<u>28261 Turkey Run Road</u>
City, State Zip Code	<u>Bloxom, Virginia 23308</u>

The claim must include the following information: (a) a deed or other available evidence that the claimant is the owner of the well and the well was constructed and operated prior to the effective date of the permit; (b) all available information related to well construction, water levels, historic yield, water quality, and the exact location of the well sufficient to allow Danny P. Huynh to locate the well on the claimant's property; (c) the reasons the claimant believes that the Tai Dat Farm withdrawal has caused an adverse impact on the claimants well(s).

CLAIM RESOLUTION

Danny P. Huynh will review any claim within **five (5) business days**. If Tai Dat Farm determines that no rebuttal will be made and accepts the claim as valid, Danny P. Huynh will so notify the claimant and will implement mitigation within **thirty (30) business days**. If the claim is not accepted as valid, Danny P. Huynh will notify the claimant that (a) the claim is denied **or** (b) that additional documentation from the claimant is required in order to evaluate the claim. Within **fifteen (15) business days** of receiving additional documentation from the claimant, Tai Dat Farm will notify the claimant (a) that Danny P. Huynh agrees to mitigate adverse impacts or (b) the claim is denied. If the claim is denied, the claimant will be notified that the claimant may request the claim be evaluated by a three (3) member committee. This committee will consist of one (1) representative selected by Tai Dat Farm, one (1) representative selected by the claimant, and one (1) representative mutually agreed upon by the claimant and (Guise).

Any claimant requesting that a claim be evaluated by the committee should provide the name and address of their representative to Danny P. Huynh. Within **five (5) business days** of receipt of such notification, Danny P. Huynh will notify the claimant and claimant's representative of the identity of Tai Dat Farm representative and instruct the representatives to select a third representative within **ten (10) business days**. Representatives should be a professional engineer or hydrogeologist with experience in the field of groundwater hydrology. Danny P. Huynh agrees to reimburse the members of the committee for reasonable time spent, at a rate prevailing in the area for experts in the above listed fields, and for direct costs incurred in administering the plan. The claimant may, at his or her option, choose to provide the reimbursement for the member of the committee selected by the claimant and up to half of the reimbursement for the mutual representative.

Within **ten (10) business days** of selection of the third representative, the committee will establish a **reasonable deadline** for submission of all documentation it needs to evaluate the claim. Both the claimant and Danny P. Huynh will abide by this deadline.

Within **fifteen (15) business days** of receipt of documentation, the committee will evaluate the claim and reach a decision by majority vote. The committee will notify the claimant regarding its decision to (a) deny or (b) approve the claim. If the claim is approved, Danny P. Huynh will mitigate the adverse impacts within **thirty (30) business days** of making the decision or as soon as practical. If the claim is denied by the committee, Tai Dat Farm may seek

reimbursement from the claimant for the claimant's committee representative and one half of the 3rd representative on the committee

If a claimant within the indicated area of impact indicates that they are out of water, Tai Dat Farm will accept the responsibility of providing water for human consumptive needs within **seventy-two (72) hours** and to cover the claim review period. Tai Dat Farm reserves the right to recover the cost of such emergency supply if the claim is denied by Danny P. Huynh or found to be fraudulent or frivolous. If () denies a claim and the claimant elects to proceed with the three (3) member committee, Danny P. Huynh will continue the emergency water supply at the claimant's request during the committee's deliberations but reserves the right to recover the total costs of emergency water supply in the case that the committee upholds the denial of the claim. Similarly, Danny P. Huynh reserves the right to recover costs associated with the claim process if a claim is found to be fraudulent or frivolous.


If it is determined by the committee or shown to the committee's satisfaction that a well operating under a mitigation plan similar to Danny P. Huynh/Tai Dat Farm Plan other than those owned and operated by Danny P. Huynh has contributed to the claimed adverse impact, Danny P. Huynh share of the costs associated with mitigation will be allocated in proportion to its share of the impact. Such a determination shall be made by the committee after notification of the third party well owner, giving the third party well owner opportunity to participate in the proceedings of the committee.

PLAN ADMINISTRATION

Nothing in the Plan shall be construed to prevent the Department of Environmental Quality Staff from providing information needed for resolution of claims by the committee.

Tai Dat LLC

Area of Impact - Lower Yorktown-Eastover Aquifer



● Tai Dat LLC Wells

○ Lower Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Lower Yorktown-Eastover aquifer resulting from a 9,400,000 gallons per year (25,753 average gpd), 50 year, Lower Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.

Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.7 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018



totals for application
item unlike to be needed, but there just in case

cells requiring entry, if applicable

CONSUMPTION			
(for all houses)			
Max Annual	gal/flock	# flocks/yr	gallons/year
	614,260	5.5	3,378,430
Monthly	(highest 30 days)		
Day	total gallons- all houses		
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
			or provided
			514,260

COOLING					
if all houses equal size					
tunnel fan capacity	1.6 gpy/1cfm	total cool/house	# of houses	Max annual for cooling	Max mo. for cooling
376,200	1.6	601,920	10	6,019,200	2,006,400
if house size varies					
1-tunnel fan capacity	# of houses	cfm-cubic feet/min	to calculate tunnel fan capacity 1.6 gpy/1cfm auto enable (0) auto disable (1)		
cfm/house	# of houses	0			
cfm/house	# of houses	0			
cfm/house	# of houses	0			
cfm/house	# of houses	0			
		1.6 gpy/1cfm	Max annual for cooling	Max mo. for cooling	
		0	1.6	0	

REQUESTED WITHDRAWAL AMOUNTS					
ANNUAL					
Consumption	Cooling	Max Annual	rounded	(nearest 100K)	
3,378,430	6,019,200	9,397,630	9,400,000	annual rounding	
if other usages					
other ag	human	Total Max Annual	rounded	(nearest 100K)	
		9,397,630		annual rounding	
MONTHLY					
Consumption	Max Mo. Cool	Max monthly	rounded	(nearest 100K)	
514,260	2,006,400	2,520,660	2,500,000	annual rounding	
if other usages					
other ag	human	Total Max Mo.	rounded	(nearest 100K)	
		2,520,660		annual rounding	

Tai Dat Farm

9,400,000 Annual
2,500,000 monthly

Danny Huynh Tai Dat Farm

Farm Name: _____

County: ACCOMACK

Permit Application Water Usage Calculations

Facility Information

_____ houses @ 40 ft width

_____ houses @ 50 ft width

_____ houses @ 60 ft width

10 houses @ 66 ft width

_____ flocks per year

Consumption

Attach a farm-specific table of daily water consumption data for one (1) flock. (See attached example table)

Assuming that water consumption remains generally constant from flock to flock, the annual flock consumption may be estimated as follows:

$$\text{Annual Flock Consumption} = \frac{61,426}{\text{flock}} \times \frac{5.5}{\text{yr}} = \frac{337,843}{\text{yr}}$$

$\begin{array}{r} \times 10 \\ \hline 3,378,430 \end{array}$

The maximum monthly flock consumption may be estimated by adding up the daily water consumption for the last 31 days of the flock cycle (typically Days 20-50 of a 50 day flock cycle).

$$\text{Max Monthly Flock Consumption} = \sum_{\text{Day 20}}^{\text{Day 50}} \text{Daily Water Consumption} = \frac{51,426}{\text{mo}}$$

$\begin{array}{r} \times 10 \\ \hline 514,260 \end{array}$

Cooling

Per Figure 12 of University of Georgia, Poultry Housing Tips (Evaporative Cooling Pad System Water Usage), Volume 29, Number 1, 2017, the evaporative cooling pad water usage per tunnel fan capacity is estimated as follows:

$$\text{Annual Unit Cooling (Easton, MD)} \approx \frac{160,000 \frac{\text{gal}}{\text{yr}}}{100,000 \text{ cfm}} \approx \frac{1.6 \frac{\text{gal}}{\text{yr}}}{1 \text{ cfm}}$$

Per Page 6 of Cobb-Vantress, Broiler Management Guide, November 15, 2013, the tunnel fan capacity (operating at an airspeed of 600 fpm) may be estimated as follows:

Tunnel Fan Capacity

$$\begin{aligned} &= \left[228,000 \frac{\text{cfm}}{40 \text{ ft width}} \times \text{_____ houses @ 40 ft width} \right] \\ &+ \left[285,000 \frac{\text{cfm}}{50 \text{ ft width}} \times \text{_____ houses @ 50 ft width} \right] \\ &+ \left[342,000 \frac{\text{cfm}}{60 \text{ ft width}} \times \text{_____ houses @ 60 ft width} \right] \\ &+ \left[376,200 \frac{\text{cfm}}{66 \text{ ft width}} \times \underline{10} \text{ houses @ 66 ft width} \right] \\ &= \underline{3'726'000} \text{ cfm} \end{aligned}$$

Given the annual unit cooling and tunnel fan capacity, the annual cooling may be estimated as follows:

$$\text{Annual Cooling} = \underline{3'726'000} \text{ cfm} \times \frac{1.6 \frac{\text{gal}}{\text{yr}}}{1 \text{ cfm}} = \underline{6'019'200} \frac{\text{gal}}{\text{yr}}$$

Requested Withdrawal Amounts

The total annual withdrawal amount may be estimated by adding the annual flock consumption and the annual cooling amounts.

$$\text{Annual Amount} = \underline{3'318'430} \frac{\text{gal}}{\text{yr}} + \frac{\overset{6,019,200}{\cancel{3'226'000}} \frac{\text{gal}}{\text{yr}}}{\overset{9,400,000}{\cancel{3'226'000}}} = \underline{7'104'430} \frac{\text{gal}}{\text{yr}}$$

The total monthly withdrawal amount may be estimated by adding the maximum monthly flock consumption amount and one-third of the annual cooling amount (annual cooling divided by 3).

$$\text{Monthly Amount} = \underline{514,260} \frac{\text{gal}}{\text{mo}} + \left[\frac{\overset{6,019,200}{\cancel{2'666'400}} \frac{\text{gal}}{\text{yr}}}{3} \right] = \underline{2'882'403} \frac{\text{gal}}{\text{mo}}$$

↓

2,006,400